



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Haddon Elementary School

501 West Redman Avenue
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 03/07/2017 04:55 - 05:51

Date & Time Analyzed: 03/22/2017 11:29 - 17:54

Date & Time Analyzed: 03/23/2017 10:35 - 11:20

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
HADD-KC-02-KIT(1)	3.04	15.5
HADD-KC-02-KIT(2)	2.55	15.5
HADD-KC-02-KIT(3)	8.51	15.5
HADD-CS-02-103	2.88	15.5
HADD-CS-02-101	4.53	15.5
HADD-DW-02-101	8.14	15.5
HADD-CS-01-04	2.58	15.5
HADD-WC-02-HALL1	2.28	15.5
HADD-WC-03-HALL2	<2.00	15.5
HADD-TL-01-FAC	<2.00	15.5
HADD-CS-02-104	8.40	15.5
HADD-CS-03-206	4.81	15.5
HADD-WC-03-HALL1	<2.00	15.5
HADD--CS-02-106	10.2	15.5
HADD-NS-02-NURSE	<2.00	15.5
HADD-WC-02-HALL1A	<2.00	15.5
HADD-WC-02-HALL1B	<2.00	15.5
HADD-CS-03-208	50.0	15.5
HADD-SO-02-LIBOF	5.17	15.5
HADD-WC-02-HALL2	<2.00	15.5
HADD-DW-02-110	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Haddon Elementary School

501 West Redman Avenue
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 03/07/2017 04:55 - 05:51

Date & Time Analyzed: 03/22/2017 11:29 - 17:54

Date & Time Analyzed: 03/23/2017 10:35 - 11:20

Sample Location	First Draw	Action Level
HADD-DW-02-112	<2.00	15.5
HADD-DW-02-114	<2.00	15.5
HADD-DW-02-116	9.04	15.5
HADD-DW-02-118	4.64	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

3-30-17

Date



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006
Professional Septic Inspections

Haddon Elementary School

501 West Redman Avenue
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 03/07/2017 05:38

Date & Time Analyzed: 03/23/2017 10:36

Sample Location	Flushed	Action Level
HADD-CS-03-208	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.
Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

3/30/17

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: Fax: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61710	HADD-FB	3/7/17	0455	D	1 x 250	HNO3	First Draw Lead	FIELD BLANK
P61711	HADD-KC-02-KIT(1)		0457	D	1 x 250	HNO3	First Draw Lead	
P61712	HADD-KC-02-KIT(2)		0457	D	1 x 250	HNO3	First Draw Lead	
P61713	HADD-KC-02-KIT(3)		0459	D	1 x 250	HNO3	First Draw Lead	
P61714	HADD-CS-02-103		0503	D	1 x 250	HNO3	First Draw Lead	
P61715	HADD-CS-02-101		0506	D	1 x 250	HNO3	First Draw Lead	
P61716	HADD-DW-02-101		0508	D	1 x 250	HNO3	First Draw Lead	
P61717	HADD-CS-01-04		0510	D	1 x 250	HNO3	First Draw Lead	
P61718	HADD-WC-02-HA01		0512	D	1 x 250	HNO3	First Draw Lead	
P61719	HADD-WC-03-HA02		0514	D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp °C Properly Preserved Yes No
--	---	--	---

Sampled by: (Print) James Eberts (Signature) <i>James Eberts</i>	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300	Time 1300
Relinquished by: (Signature) <i>James Eberts</i>	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Fax: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61720	HADD-TL-01-FAC	3/7/17	0515	X	D	1 x 250	HNO3	First Draw Lead	
P61721	HADD-CS-02-104		0518	X	D	1 x 250	HNO3	First Draw Lead	
P61722	HADD-CS-03-206		0521	X	D	1 x 250	HNO3	First Draw Lead	
P61723	HADD-WC-03-HALL1		0523	X	D	1 x 250	HNO3	First Draw Lead	
P61724	HADD-CS-02-106		0524	X	D	1 x 250	HNO3	First Draw Lead	
P61725	HADD-NS-02-NURSE		0526	X	D	1 x 250	HNO3	First Draw Lead	
P61726	HADD-WC-02-HALL1A		0534	X	D	1 x 250	HNO3	First Draw Lead	
P61727	HADD-WC-02-HALL1B		0536	X	D	1 x 250	HNO3	First Draw Lead	
P61728	HADD-CS-03-208		0537	X	D	1 x 250	HNO3	First Draw Lead	
P61729	HADD-SO-02-CB0F		0540	X	D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp °C Properly Preserved Yes No
--	---	--	---

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Fax:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61730	HADD-WC-02-HA02	3/7/17	0542	X		D	1 x 250	HNO3	First Draw Lead	
P61731	HADD-DW-02-110		0543	X		D	1 x 250	HNO3	First Draw Lead	
P61732	HADD-DW-02-112		0545	X		D	1 x 250	HNO3	First Draw Lead	
P61733	HADD-DW-02-114		0547	X		D	1 x 250	HNO3	First Draw Lead	
P61734	HADD-DW-02-116		0549	X		D	1 x 250	HNO3	First Draw Lead	
P61735	HADD-DW-02-118		0551	X		D	1 x 250	HNO3	First Draw Lead	
	end of samples			X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL S: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp °C Properly Preserved Yes No
--	---	--	---

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/6/17	Date 3/6/17	Time 1300	Time 1300
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Date	Time	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time	Time

CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	HADD-KC-02-KIT(1)	3/7/17	0458	D	1 x 250	HNO3	Flushed Lead	
	HADD-KC-02-KIT(2)		0458	D	1 x 250	HNO3	Flushed Lead	
	HADD-KC-02-KIT(3)		0500	D	1 x 250	HNO3	Flushed Lead	
	HADD-CS-02-103		0504	D	1 x 250	HNO3	Flushed Lead	
	HADD-CS-02-101		0507	D	1 x 250	HNO3	Flushed Lead	
	HADD-DW-02-101		0509	D	1 x 250	HNO3	Flushed Lead	
	HADD-CS-01-04		0511	D	1 x 250	HNO3	Flushed Lead	
	HADD-WC-02-HALL1		0612	D	1 x 250	HNO3	Flushed Lead	
	HADD-WC-03-HALL2		0613	D	1 x 250	HNO3	Flushed Lead	
	HADD-TL-01-FAC		0516	D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SW/SURFACE WATER WWWASTE WATER

Turnaround Time X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	Cooler Temp °C Properly Preserved Yes No
---	--	---	---

Sampled by: <i>James Eberts</i> (Print)	Received by: <i>[Signature]</i> (Signature)	Date: 3/10/17 Time: 1300	Date: 3/10/17 Time: 1300
Relinquished by: _____ (Signature)	Received by: _____ (Signature)	Date: _____ Time: _____	Date: _____ Time: _____
Relinquished by: _____ (Signature)	Received by: _____ (Signature)	Date: _____ Time: _____	Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	HADD-CS-02-104	3/7/17	0519	D	1 x 250	HNO3	Flushed Lead	
	HADD-CS-03-206		0522	D	1 x 250	HNO3	Flushed Lead	
	HADD-WC-03-HALL1		0614	D	1 x 250	HNO3	Flushed Lead	
	HADD-CS-02-106		0525	D	1 x 250	HNO3	Flushed Lead	
	HADD-NS-02-NURSE		0615	D	1 x 250	HNO3	Flushed Lead	
	HADD-WC-02-HALL1A		0617	D	1 x 250	HNO3	Flushed Lead	
	HADD-WC-02-HALL1B		0618	D	1 x 250	HNO3	Flushed Lead	
962320	HADD-CS-03-208		0538	D	1 x 250	HNO3	Flushed Lead	
	HADD-SO-02-LIBOF		0541	D	1 x 250	HNO3	Flushed Lead	
	HADD-WC-02-HALL2		0616	D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE G=GROUND WATER SW=SURFACE WATER WWW=WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	Cooler Temp °C Properly Preserved Yes No
--	--	---	---

Sampled by: *James Eberts*

Sampled by/Relinquished by: *James Eberts* Date: *3/16/17* Time: *1300*

Relinquished by: _____ Date: _____ Time: _____

Relinquished by: _____ Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwaterest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	HADD-DW-02-110	3/7/17	0544	D	1 x 250	HNO3	Flushed Lead	
	HADD-DW-02-112		0546	D	1 x 250	HNO3	Flushed Lead	
	HADD-DW-02-114		0548	D	1 x 250	HNO3	Flushed Lead	
	HADD-DW-02-116		0550	D	1 x 250	HNO3	Flushed Lead	
	HADD-DW-02-118		0552	D	1 x 250	HNO3	Flushed Lead	
	end of samples							

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWSURFACE WATER WWWWASTE WATER

Turnaround Time X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	Cooler Temp _____ °C
	Properly Preserved Yes _____ No _____		

Sampled by: <i>James Eberts</i> (Print)	Received by: <i>[Signature]</i> (Signature)	Date: 3/10/17 Time: 1300	Date: 3/10/17 Time: 1300
Relinquished by: <i>[Signature]</i> (Signature)	Received by: _____ (Signature)	Date: _____ Time: _____	Date: _____ Time: _____
Relinquished by: _____ (Signature)	Received by: _____ (Signature)	Date: _____ Time: _____	Date: _____ Time: _____