



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Haddonfield High School

401 Kings Highway East
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 03/10/2017 05:00 - 06:21


Date & Time Analyzed: 03/24/2017 13:08 - 14:08

Date & Time Analyzed: 03/27/2017 15:09 - 17:59

Date & Time Analyzed: 03/28/2017 10:53 - 13:07

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
HHS-NS-02-NURSE	5.56	15.5
HHS-SO-02-NRR1	3.34	15.5
HHS-SO-02-NRR2	<2.00	15.5
HHS-WC-02-HALL10	18.9	15.5
HHS-WC-02-HALL11	4.07	15.5
HHS-WC-02-HALL9	<2.00	15.5
HHS-SO-02-MNOFF	3.53	15.5
HHS-WC-02-HALL7	<2.00	15.5
HHS-WC-02-HALL12	20.6	15.5
HHS-WC-02-HALL6	<2.00	15.5
HHS-WC-02-HALL8	3.10	15.5
HHS-WC-02-HALL13	<2.00	15.5
HHS-WC-01-HALL1	<2.00	15.5
HHS-CF-01-KITCH	1280	15.5
HHS-KC-01-KITCH	3.12	15.5
HHS-IM-01-KHALL2	<2.00	15.5
HHS-HB-01-KHALL	<2.00	15.5
HHS-IM-01-KHALL1	<2.00	15.5
HHS-DW-01-CAFÉ	4.63	15.5
HHS-WC-01-CAFÉ	5.50	15.5
HHS-WC-01-WGTRM	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Haddonfield High School

401 Kings Highway East
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 03/10/2017 05:00 - 06:21

Date & Time Analyzed: 03/24/2017 13:08 - 14:08

Date & Time Analyzed: 03/27/2017 15:09 - 17:59

Date & Time Analyzed: 03/28/2017 10:53 - 13:07

Sample Location	First Draw	Action Level
HHS-WC-02-HALL4	12.5	15.5
HHS-CS-02-108	6.25	15.5
HHS-SO-01-WREST	12.0	15.5
HHS-WC-01-HALL2	<2.00	15.5
HHS-WC-01-HALL3	4.75	15.5
HHS-WC-02-HALL2	<2.00	15.5
HHS-WC-02-HALL3	4.02	15.5
HHS-WC-02-HALL1	<2.00	15.5
HHS-SO-02-MEDIA	9.87	15.5
HHS-CS-02-C204	4.73	15.5
HHS-WC-02-HALL14	<2.00	15.5
HHS-WC-02-HALL15	4.11	15.5
HHS-CS-02-C212(4)	<2.00	15.5
HHS-CS-02-C212(5)	<2.00	15.5
HHS-CS-02-C212(6)	2.19	15.5
HHS-CS-02-C212(1)	2.08	15.5
HHS-CS-02-C212(2)	<2.00	15.5
HHS-CS-02-C212(3)	3.15	15.5
HHS-CS-02-C214(2)	<2.00	15.5
HHS-CS-02-C214(1)	2.61	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Haddonfield High School

401 Kings Highway East
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 03/10/2017 05:45 - 05:38

Date & Time Analyzed: 03/24/2017 14:03

Date & Time Analyzed: 03/27/2017 16:08

Date & Time Analyzed: 03/28/2017 13:07

Sample Location	Flushed	Action Level
HHS-WC-02-HALL10	<2.00	15.5
HHS-WC-02-HALL12	<2.00	15.5
HHS-CF-01-KITCH	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.
Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

3-30-17

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Lab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61809	HHS-FB	3/10/17	0500	X		D	1 x 250	HNO3	First Draw Lead	FIELD BLANK
P61810	HHS-NS-02-NURSE		0504	X		D	1 x 250	HNO3	First Draw Lead	
P61811	HHS-SO-02-NRR1		0506	X		D	1 x 250	HNO3	First Draw Lead	
P61812	HHS-SO-02-NRR2		0506	X		D	1 x 250	HNO3	First Draw Lead	
P61813	HHS-WC-02-HALL10		0508	X		D	1 x 250	HNO3	First Draw Lead	
P61814	HHS-WC-02-HALL11		0510	X		D	1 x 250	HNO3	First Draw Lead	
P61815	HHS-WC-02-HALL9		0512	X		D	1 x 250	HNO3	First Draw Lead	
P61816	HHS-SO-02-MNOFF		0513	X		D	1 x 250	HNO3	First Draw Lead	
P61817	HHS-WC-02-HALL7		0515	X		D	1 x 250	HNO3	First Draw Lead	
P61818	HHS-WC-02-HALL12		0516	X		D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions	Cooler Temp
		Analyze All	°C Properly Preserved Yes No

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Time 1300
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077
Fax:

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61819	HHS-WC-02-HALL6	3/10/17	0518	D	1 x 250	HNO3	First Draw Lead	
P61820	HHS-WC-02-HALL8		0519	D	1 x 250	HNO3	First Draw Lead	
P61821	HHS-WC-02-HALL13		0520	D	1 x 250	HNO3	First Draw Lead	
P61822	HHS-WC-01-HALL1		0530	D	1 x 250	HNO3	First Draw Lead	
P61823	HHS-CF-01-KITCH		0537	D	1 x 250	HNO3	First Draw Lead	
P61824	HHS-KC-01-KITCH		0539	D	1 x 250	HNO3	First Draw Lead	2 BOTTLES
P61825	HHS-IM-01-KHALL2		0541	D	1 x 250	HNO3	First Draw Lead	
P61826	HHS-HB-01-KHALL		0541	D	1 x 250	HNO3	First Draw Lead	
P61827	HHS-IM-01-KHALL1		0544	D	1 x 250	HNO3	First Draw Lead	2 BOTTLES
P61828	HHS-DW-01-CAFE		0546	D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D=DRINKING WATER AWAQUEOUS S=SOIL SL=SLUDGE GW=GROUND WATER SW=SURFACE WATER WW=WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp °C
	Properly Preserved Yes No		

Sampled by: (Print) James Eberts	Received by: (Signature) [Signature]	Date 3/10/17	Date 3/10/17	Time 1300	Time 1300
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date	Date	Time	Time
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date	Date	Time	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077
Fax:

Lab ID#	Sample Location	Collection Date	Time	Lab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61829	HHS-WC-01-CAFE	3/10/17	0548	X		D	1 x 250	HNO3	First Draw Lead	
P61830	HHS-WC-01-WGTBM		0549	X		D	1 x 250	HNO3	First Draw Lead	
P61831	HHS-WC-02-HALL4		0551	X		D	1 x 250	HNO3	First Draw Lead	
P61832	HHS-CS-02-10P		0554	X		D	1 x 250	HNO3	First Draw Lead	
P61833	HHS-S0-01-WREST		0555	X		D	1 x 250	HNO3	First Draw Lead	
P61834	HHS-WC-01-HALL2		0557	X		D	1 x 250	HNO3	First Draw Lead	
P61835	HHS-WC-01-HALL3		0559	X		D	1 x 250	HNO3	First Draw Lead	
P61836	HHS-WC-02-HALL2		0602	X		D	1 x 250	HNO3	First Draw Lead	
P61837	HHS-WC-02-HALL3		0603	X		D	1 x 250	HNO3	First Draw Lead	
P61838	HHS-WC-02-HALL1		0604	X		D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AWAQUEOUS SISOIL SL/SLUDGE GWGROUND WATER SWMSURFACE WATER WWWWASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp °C Properly Preserved Yes No
--	---	--	---

Sampled by: (Print) James Eberts (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: Fax: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Comp	Tab	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61839	HHS-S0-02-MEDIA	3/10/17	0606	X		D	1 x 250	HNO3	First Draw Lead	
P61840	HHS-CS-02-C204		0609	X		D	1 x 250	HNO3	First Draw Lead	
P61841	HHS-WC-02-HAGU14		0611	X		D	1 x 250	HNO3	First Draw Lead	
P61842	HHS-WC-02-HAGU15		0612	X		D	1 x 250	HNO3	First Draw Lead	
P61843	HHS-CS-02-C212(4)		0613	X		D	1 x 250	HNO3	First Draw Lead	
P61844	HHS-CS-02-C212(5)		0613	X		D	1 x 250	HNO3	First Draw Lead	
P61845	HHS-CS-02-C212(6)		0613	X		D	1 x 250	HNO3	First Draw Lead	
P61846	HHS-CS-02-C212(1)		0617	X		D	1 x 250	HNO3	First Draw Lead	
P61847	HHS-CS-02-C212(2)		0617	X		D	1 x 250	HNO3	First Draw Lead	
P61848	HHS-CS-02-C212(3)		0617	X		D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp °C	
	Date 3/10/17	Time 1300	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17
Date 3/10/17	Time 1300	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Time 1300
Date 3/10/17	Time 1300	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Time 1300

Sampled by: (Print) James Eberts

Sampled by/Relinquished by: (Signature) *[Signature]*

Relinquished by: (Signature) *[Signature]*

Relinquished by: (Signature) *[Signature]*

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwaterest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077
Fax:

Lab ID#	Sample Location	Collection Date	Time	Lab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61849	HHCS-02-C214(2)	3/10/17	0621	X		D	1 x 250	HNO3	First Draw Lead	
P61850	HHCS-02-C214(1)	↓	0621	X		D	1 x 250	HNO3	First Draw Lead	
	← end of samples			X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	
				X		D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp °C
	Yes	No	Properly Preserved

Sampled by: (Print) James Eberts	Received by: (Signature) [Signature]	Date 3/10/17	Time 1300
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date	Time
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date	Time

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone: **Fax:**
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	HHS-NS-02-NURSE	3/10/17	0505	D	1 x 250	HNO3	Flushed Lead	
	HHS-SO-02-NER1		0507	D	1 x 250	HNO3	Flushed Lead	
	HHS-SO-02-NER2		0507	D	1 x 250	HNO3	Flushed Lead	
P62417	HHS-WC-02-HALL10		0545	D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL11		0546	D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL9		0547	D	1 x 250	HNO3	Flushed Lead	
	HHS-SO-02-MNOFF		0514	D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL7		0548	D	1 x 250	HNO3	Flushed Lead	
P62525	HHS-WC-02-HALL12		0549	D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL6		0550	D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE GW=GROUND WATER SW=SURFACE WATER WW=WASTE WATER

Turnaround Time	<input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____			Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	°C
				Yes No

Sampled by: (Print) James Eberts

Sampled by/Relinquished by: (Signature) *James Eberts*

Relinquished by: (Signature) _____

Relinquished by: (Signature) _____

Date	Time	Received by:	Date	Time
3/10/17	1300	(Signature) <i>James Eberts</i>	3/10/17	1300
Date	Time	Received by:	Date	Time
		(Signature) _____		
Date	Time	Received by:	Date	Time
		(Signature) _____		

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	HHS-WC-02-HALL 8	3/10/17	0551	D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL 13		0552	D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-01-HALL 1		0600	D	1 x 250	HNO3	Flushed Lead	
P62474	HHS-CF-01-KITCH		0538	D	1 x 250	HNO3	Flushed Lead	
	HHS-KC-01-KITCH		0540	D	1 x 250	HNO3	Flushed Lead	
	HHS-HB-01-KHALL		0542	D	1 x 250	HNO3	Flushed Lead	
	HHS-DW-01-CAFE		0547	D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-01-CAFE		0637	D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-01-WGTEM		0638	D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL 4		0639	D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWSURFACE WATER WW/WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.		Cooler Temp °C
		Yes	No	Properly Preserved

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) _____	Date	Date	Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Q	g	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	HHS-CS-02-108	3/10/17	0555	X		D	1 x 250	HNO3	Flushed Lead	
	HHS-SO-01-WREST		0536	X		D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-01-HALL 2		0640	X		D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-01-HALL 3		0641	X		D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL 2		0642	X		D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL 3		0643	X		D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL 1		0644	X		D	1 x 250	HNO3	Flushed Lead	
	HHS-SO-02-MEDIA		0607	X		D	1 x 250	HNO3	Flushed Lead	
	HHS-CS-02-C204		0610	X		D	1 x 250	HNO3	Flushed Lead	
	HHS-WC-02-HALL 4		0645	X		D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWT A Format	Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	°C
		Yes	No

Sampled by: (Print) James Eberts (Signature) <i>James Eberts</i>	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300	Time 1300
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date	Date	Time	Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date	Date	Time	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: Fax: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	HHS-WC-02-HALLIS	3/10/17	0646	D	1 x 250	HNO3	Flushed Lead	
	HHS-CS-02-C212(4)		0614	D	1 x 250	HNO3	Flushed Lead	
	HHS-CS-02-C212(5)		0614	D	1 x 250	HNO3	Flushed Lead	
	HHS-CS-02-C212(6)		0614	D	1 x 250	HNO3	Flushed Lead	
	HHS-CS-02-C212(1)		0618	D	1 x 250	HNO3	Flushed Lead	
	HHS-CS-02-C212(2)		0618	D	1 x 250	HNO3	Flushed Lead	
	HHS-CS-02-C212(3)		0618	D	1 x 250	HNO3	Flushed Lead	
	HHS-CS-02-C212(2)		0622	D	1 x 250	HNO3	Flushed Lead	
	HHS-CS-02-C214(1)		0622	D	1 x 250	HNO3	Flushed Lead	
	end of samples			D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.		Cooler Temp °C
		Yes	Properly Preserved	No

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time (300)
Sampled by/Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time