



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Tatem Elementary School

1 Glover Avenue
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 03/08/2017 05:00 - 06:22

Date & Time Analyzed: 03/23/2017 11:20 - 17:53

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
TATE-KC-KITCH1	<2.00	15.5
TATE-KC-KITCH2	2.58	15.5
TATE-KC-KITCH3	<2.00	15.5
TATE-NS-01-NURSE	<2.00	15.5
TATE-WC-01-HALL1	<2.00	15.5
TATE-WC-01-HALL2	<2.00	15.5
TATE-CS-01-106(5)	10.9	15.5
TATE-CS-01-106(4)	7.07	15.5
TATE-CS-01-106(3)	6.60	15.5
TATE-CS-01-106(2)	10.2	15.5
TATE-CS-01-106(1)	66.7	15.5
TATE-WC-01-HALL3	<2.00	15.5
TATE-TL-01-FACUL	<2.00	15.5
TATE-TATE-01-LIBOF	12.9	15.5
TATE-CS-02-211	5.89	15.5
TATE-CS-02-209	6.39	15.5
TATE-CS-02-210	3.67	15.5
TATE-CS-02-208	<2.00	15.5
TATE-CS-03-311	5.95	15.5
TATE-CS-03-309	5.40	15.5
TATE-WC-03-HALL1	<2.00	15.5
TATE-CS-03-310	2.47	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Tatem Elementary School

1 Glover Avenue
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 03/08/2017 05:00 - 06:22

Date & Time Analyzed: 03/23/2017 11:20 - 17:53

Sample Location	First Draw	Action Level
TATE-CS-03-308	4.88	15.5
TATE-CS-02-207	4.69	15.5
TATE-CS-03-307	2.66	15.5
TATE-WC-02-HALL1	2.73	15.5
TATE-WC-03-HALL2	5.72	15.5
TATE-CS-02-204	5.84	15.5
TATE-CS-03-204	5.78	15.5
TATE-DW-01-102	<2.00	15.5
TATE-DW-01-103	<2.00	15.5
TATE-DW-01-101	<2.00	15.5
TATE-DW-01-100	<2.00	15.5
TATE-DW-02-205	<2.00	15.5
TATE-DW-02-202	<2.00	15.5
TATE-DW-02-203	<2.00	15.5
TATE-DW-02-201	<2.00	15.5
TATE-DW-02-200	<2.00	15.5
TATE-DW-03-305	<2.00	15.5
TATE-DW-03-303	<2.00	15.5
TATE-DW-03-301	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Tatem Elementary School

1 Glover Avenue
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 03/08/2017 05:13


Date & Time Analyzed: 03/23/2017 17:53

Sample Location	Flushed	Action Level
TATE-CS-01-106(1)	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.
Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

3-30-17
Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61736	TATE-FB	3/8/17	0500	D	1 x 250	HNO3	First Draw Lead	FIELD BLANK
P61737	TATE-KC-KITCH1		0504	D	1 x 250	HNO3	First Draw Lead	
P61738	TATE-KC-KITCH2		0504	D	1 x 250	HNO3	First Draw Lead	
P61739	TATE-KC-KITCH3		0504	D	1 x 250	HNO3	First Draw Lead	
P61740	TATE-NS01-MURSE		0508	D	1 x 250	HNO3	First Draw Lead	
P61741	TATE-WC-01-HAUG1		0510	D	1 x 250	HNO3	First Draw Lead	
P61742	TATE-WC-01-HAUG2		0511	D	1 x 250	HNO3	First Draw Lead	
P61743	TATE-CS-01-106 (5)		0512	D	1 x 250	HNO3	First Draw Lead	
P61744	TATE-CS-01-106 (4)		0512	D	1 x 250	HNO3	First Draw Lead	
P61745	TATE-CS-01-106 (3)		0512	D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp _____ °C Properly Preserved Yes _____ No _____
--	---	--	---

Sampled by: (Print) James Eberts (Signature) <i>James Eberts</i>	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300	Time 1300
Relinquished by: (Signature) <i>James Eberts</i>	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	G Lab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61746	TATE-CS-01-106(2)	3/8/17	0512	X		D	1 x 250	HNO3	First Draw Lead	
P61747	TATE-CS-01-106(1)		0512	X		D	1 x 250	HNO3	First Draw Lead	
P61748	TATE-WC-01-HAL3		0522	X		D	1 x 250	HNO3	First Draw Lead	
P61749	TATE-TL-01-FAUG		0523	X		D	1 x 250	HNO3	First Draw Lead	
P61750	TATE-SO-01-LIBOF		0525	X		D	1 x 250	HNO3	First Draw Lead	
P61751	TATE-CS-02-211		0529	X		D	1 x 250	HNO3	First Draw Lead	
P61752	TATE-CS-02-209		0530	X		D	1 x 250	HNO3	First Draw Lead	
P61753	TATE-CS-02-210		0532	X		D	1 x 250	HNO3	First Draw Lead	
P61754	TATE-CS-02-208		0533	X		D	1 x 250	HNO3	First Draw Lead	
P61755	TATE-CS-03-311		0536	X		D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AWAQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp _____ °C Properly Preserved Yes _____ No _____
--	---	--	---

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Time 1300
Sampled by/Relinquished by: (Signature) Jan P. [Signature]	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Time 1300
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Time _____
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Time _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077
Fax:

Lab ID#	Sample Location	Collection		Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
		Date	Time					
P61756	TATE-CS-03-309	3/8/17	0538	D	1 x 250	HNO3	First Draw Lead	
P61757	TATE-WC-03-HALL1		0540	D	1 x 250	HNO3	First Draw Lead	
P61758	TATE-CS-03-310		0542	D	1 x 250	HNO3	First Draw Lead	
P61759	TATE-CS-03-308		0543	D	1 x 250	HNO3	First Draw Lead	
P61760	TATE-CS-02-207		0546	D	1 x 250	HNO3	First Draw Lead	
P61761	TATE-CS-03-307		0548	D	1 x 250	HNO3	First Draw Lead	
P61762	TATE-WC-02-HALL1		0550	D	1 x 250	HNO3	First Draw Lead	
P61763	TATE-WC-03-HALL2		0551	D	1 x 250	HNO3	First Draw Lead	
P61764	TATE-CS-02-204		0553	D	1 x 250	HNO3	First Draw Lead	
P61765	TATE-CS-03-304		0555	D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp _____ °C
	Properly Preserved Yes _____ No _____		

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) _____	Date _____	Date _____	Time _____
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61766	TATE-DW-01-102	3/8/17	0558	X		D	1 x 250	HNO3	First Draw Lead	
P61767	TATE-DW-01-103		0600	X		D	1 x 250	HNO3	First Draw Lead	
P61768	TATE-DW-01-101		0602	X		D	1 x 250	HNO3	First Draw Lead	
P61769	TATE-DW-01-108		0604	X		D	1 x 250	HNO3	First Draw Lead	
P61770	TATE-DW-02-205		0607	X		D	1 x 250	HNO3	First Draw Lead	
P61771	TATE-DW-02-202		0609	X		D	1 x 250	HNO3	First Draw Lead	
P61772	TATE-DW-02-203		0611	X		D	1 x 250	HNO3	First Draw Lead	
P61773	TATE-DW-02-201		0613	X		D	1 x 250	HNO3	First Draw Lead	
P61774	TATE-DW-02-200		0615	X		D	1 x 250	HNO3	First Draw Lead	
P61775	TATE-DW-03-305		0618	X		D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL S: SLURRY L: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp °C Properly Preserved Yes No
--	---	--	---

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300	Time 1300
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Date	Time	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time	Time

CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P61776	TATE-DW-03-303	3/8/17	0620	D	1 x 250	HNO3	First Draw Lead	
P61777	TATE-DW-03-301	↓	0622	D	1 x 250	HNO3	First Draw Lead	
	end of samples			D	1 x 250	HNO3	First Draw Lead	
				D	1 x 250	HNO3	First Draw Lead	
				D	1 x 250	HNO3	First Draw Lead	
				D	1 x 250	HNO3	First Draw Lead	
				D	1 x 250	HNO3	First Draw Lead	
				D	1 x 250	HNO3	First Draw Lead	
				D	1 x 250	HNO3	First Draw Lead	
				D	1 x 250	HNO3	First Draw Lead	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE G=GROUND WATER S=SURFACE WATER W=WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze All	Cooler Temp _____ °C
	Properly Preserved Yes _____ No _____		

Sampled by: (Print) James Eberts	Received by: (Signature) [Signature]	Date 3/10/17	Date 3/10/17	Time 1300
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date [Blank]	Date [Blank]	Time [Blank]
Relinquished by: (Signature) [Blank]	Received by: (Signature) [Blank]	Date [Blank]	Date [Blank]	Time [Blank]

South Jersey Water Test, LLC

4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	TATE-KC-KITCH 1	3/8/17	0505	D	1 x 250	HNO3	Flushed Lead	
	TATE-KC-KITCH 2		0505	D	1 x 250	HNO3	Flushed Lead	
	TATE-KC-KITCH 3		0505	D	1 x 250	HNO3	Flushed Lead	
	TATE-NS-01-NURSE		0509	D	1 x 250	HNO3	Flushed Lead	
	TATE-WC-01-HALL 1		0645	D	1 x 250	HNO3	Flushed Lead	
	TATE-WC-01-HALL 2		0646	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-01-106 (5)		0513	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-01-106 (4)		0513	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-01-106 (3)		0513	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-01-106 (2)		0513	D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SLI SLUDGE GWGROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	Cooler Temp _____ °C
			Properly Preserved <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Sampled by: <i>James Eberts</i> (Print)	Received by: <i>[Signature]</i> (Signature)	Date: 3/10/17	Date: 3/10/17	Time: 1300	Time: 1300
Relinquished by: <i>[Signature]</i> (Signature)	Received by: <i>[Signature]</i> (Signature)	Date:	Date:	Time:	Time:
Relinquished by: <i>[Signature]</i> (Signature)	Received by: <i>[Signature]</i> (Signature)	Date:	Date:	Time:	Time:

CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P62393	TATE-CS-01-106(1)	3/8/17	0513	D	1 x 250	HNO3	Flushed Lead	
	TATE-WC-01-HAUC3		0647	D	1 x 250	HNO3	Flushed Lead	
	TATE-TL-01-FACUL		0524	D	1 x 250	HNO3	Flushed Lead	
	TATE-SO-01-LIBOF		0526	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-02-211		0530	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-02-209		0531	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-02-210		0533	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-02-208		0534	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-03-311		0537	D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-03-309		0539	D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS \$ISOIL SL/SLUDGE GWGROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze flushed lead sample for any sample Location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	Cooler Temp °C Properly Preserved Yes No
---	--	---	---

Sampled by: (Print) James Eberts (Signature) <i>James Eberts</i>	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300	Time 1300
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	G	P	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	TATE-WC-03-HALL 1	3/18/17	0648	X		D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-03-310		0543	X		D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-03-308		0544	X		D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-02-207		0547	X		D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-03-307		0549	X		D	1 x 250	HNO3	Flushed Lead	
	TATE-WC-02-HALL 1		0649	X		D	1 x 250	HNO3	Flushed Lead	
	TATE-WC-03-HALL 2		0650	X		D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-02-204		0554	X		D	1 x 250	HNO3	Flushed Lead	
	TATE-CS-03-304		0556	X		D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-01-102		0559	X		D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
	<input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	°C
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____		Yes	No

Sampled by: (Print) James Eberts	Received by: (Signature)	Date 3/16/17	Date 3/16/17	Time 1300
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	TATE-DW-01-103	3/18/17	0601	D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-01-101		0603	D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-01-100		0605	D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-02-205		0608	D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-02-202		0610	D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-02-203		0612	D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-02-201		0614	D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-02-200		0616	D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-03-305		0619	D	1 x 250	HNO3	Flushed Lead	
	TATE-DW-03-303		0621	D	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	Cooler Temp °C Properly Preserved Yes No
--	--	---	---

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300	Time 1300
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterfest.com
 NJ DEP Certification #08006

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	Comp	No. of Bottles	Pres.	Analysis Requested	Comments
	TATE-DW-03-301	3/8/17	0623	D	X	1 x 250	HNO3	Flushed Lead	
	end of samples			D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	
				D	X	1 x 250	HNO3	Flushed Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	Cooler Temp _____ °C
		Properly Preserved Yes _____ No _____	

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 3/10/17	Date 3/10/17	Time 1300	Time 1300
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Date	Time	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time	Time