

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012511205
LIMS Reference ID: AD11205
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Tatem Elementary School

Customer PO:

NJ-DOE 24-1117C

EMSL Sales Rep:

Justin Monturano

Received:

02/26/2025 12:00

Reported:

03/12/2025 13:08

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: TATE-FB Lims Reference ID: AD11205-01 Matrix: Drinking Water Sampled: 02/15/25 08:58:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-KC-Kitch1 Lims Reference ID: AD11205-02 Matrix: Drinking Water Sampled: 02/15/25 09:00:00									
Metals									
Lead	3.99		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-KC-Kitch2 Lims Reference ID: AD11205-04 Matrix: Drinking Water Sampled: 02/15/25 09:00:00									
Metals									
Lead	2.35		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-KC-Kitch3 Lims Reference ID: AD11205-06 Matrix: Drinking Water Sampled: 02/15/25 09:00:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-NS-01-Nurse Lims Reference ID: AD11205-08 Matrix: Drinking Water Sampled: 02/15/25 09:05:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-WC-01-Hall1 Lims Reference ID: AD11205-10 Matrix: Drinking Water Sampled: 02/15/25 09:08:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-WC-01-Hall2 Lims Reference ID: AD11205-11 Matrix: Drinking Water Sampled: 02/15/25 09:08:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-BF-01-Hall2 Lims Reference ID: AD11205-12 Matrix: Drinking Water Sampled: 02/15/25 09:08:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-WC-01-Hall3 Lims Reference ID: AD11205-13 Matrix: Drinking Water Sampled: 02/15/25 09:13:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:50	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012511205
LIMS Reference ID: AD11205
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Tatem Elementary School

Customer PO:

NJ-DOE 24-1117C

EMSL Sales Rep:

Justin Monturano

Received:

02/26/2025 12:00

Reported:

03/12/2025 13:08

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: TATE-TL-01-Facul Lims Reference ID: AD11205-14 Matrix: Drinking Water Sampled: 02/15/25 09:14:00									
Metals									
Lead	1.13		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-SO-01-LibOf Lims Reference ID: AD11205-16 Matrix: Drinking Water Sampled: 02/15/25 09:17:00									
Metals									
Lead	9.87		1	1.00	µg/L	03/05/25 15:17	03/10/25 19:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-02-211 Lims Reference ID: AD11205-18 Matrix: Drinking Water Sampled: 02/15/25 09:21:00									
Metals									
Lead	1.22		1	1.00	µg/L	03/05/25 15:17	03/10/25 20:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-02-209 Lims Reference ID: AD11205-20 Matrix: Drinking Water Sampled: 02/15/25 09:23:00									
Metals									
Lead	2.11		1	1.00	µg/L	03/05/25 15:17	03/10/25 20:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-WC-02-Hall2 Lims Reference ID: AD11205-22 Matrix: Drinking Water Sampled: 02/15/25 09:25:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 20:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-02-210 Lims Reference ID: AD11205-23 Matrix: Drinking Water Sampled: 02/15/25 09:25:00									
Metals									
Lead	1.00		1	1.00	µg/L	03/05/25 15:17	03/10/25 20:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-02-208 Lims Reference ID: AD11205-25 Matrix: Drinking Water Sampled: 02/15/25 09:25:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 20:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-03-311 Lims Reference ID: AD11205-27 Matrix: Drinking Water Sampled: 02/15/25 09:29:00									
Metals									
Lead	2.02		1	1.00	µg/L	03/05/25 15:17	03/10/25 20:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-03-309 Lims Reference ID: AD11205-29 Matrix: Drinking Water Sampled: 02/15/25 09:30:00									
Metals									
Lead	5.09		1	1.00	µg/L	03/05/25 15:17	03/10/25 20:15	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012511205
LIMS Reference ID: AD11205
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Tatem Elementary School

Customer PO:

NJ-DOE 24-1117C

EMSL Sales Rep:

Justin Monturano

Received:

02/26/2025 12:00

Reported:

03/12/2025 13:08

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: TATE-WC-03-Hall1 Lims Reference ID: AD11205-31 Matrix: Drinking Water Sampled: 02/15/25 09:32:00									
Metals									
Lead	ND		1	1.00	µg/L	03/05/25 15:17	03/10/25 20:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-BF-03-Hall1 Lims Reference ID: AD11205-32 Matrix: Drinking Water Sampled: 02/15/25 09:32:00									
Metals									
Lead	ND		1	1.00	µg/L	03/06/25 09:47	03/10/25 22:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-03-310 Lims Reference ID: AD11205-33 Matrix: Drinking Water Sampled: 02/15/25 09:33:00									
Metals									
Lead	2.24		1	1.00	µg/L	03/06/25 09:47	03/10/25 22:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-03-308 Lims Reference ID: AD11205-35 Matrix: Drinking Water Sampled: 02/15/25 09:34:00									
Metals									
Lead	2.81		1	1.00	µg/L	03/06/25 09:47	03/10/25 22:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-02-207 Lims Reference ID: AD11205-37 Matrix: Drinking Water Sampled: 02/15/25 09:37:00									
Metals									
Lead	1.58		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-03-307 Lims Reference ID: AD11205-39 Matrix: Drinking Water Sampled: 02/15/25 09:39:00									
Metals									
Lead	1.21		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-WC-02-Hall1 Lims Reference ID: AD11205-41 Matrix: Drinking Water Sampled: 02/15/25 09:42:00									
Metals									
Lead	1.32		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-WC-03-Hall2 Lims Reference ID: AD11205-42 Matrix: Drinking Water Sampled: 02/15/25 09:43:00									
Metals									
Lead	3.84		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-CS-02-204 Lims Reference ID: AD11205-43 Matrix: Drinking Water Sampled: 02/15/25 09:45:00									
Metals									
Lead	1.14		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:11	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012511205
LIMS Reference ID: AD11205
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Tatem Elementary School

Customer PO:

NJ-DOE 24-1117C

EMSL Sales Rep:

Justin Monturano

Received:

02/26/2025 12:00

Reported:

03/12/2025 13:08

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: TATE-CS-03-304 Lims Reference ID: AD11205-45 Matrix: Drinking Water Sampled: 02/15/25 09:47:00									
Metals									
Lead	2.87		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-DW-01-102 Lims Reference ID: AD11205-47 Matrix: Drinking Water Sampled: 02/15/25 09:53:00									
Metals									
Lead	ND		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-DW-01-103 Lims Reference ID: AD11205-49 Matrix: Drinking Water Sampled: 02/15/25 09:55:00									
Metals									
Lead	1.83		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-DW-01-101 Lims Reference ID: AD11205-51 Matrix: Drinking Water Sampled: 02/15/25 09:59:00									
Metals									
Lead	1.75		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-DW-02-205 Lims Reference ID: AD11205-53 Matrix: Drinking Water Sampled: 02/15/25 10:04:00									
Metals									
Lead	ND		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-DW-02-202 Lims Reference ID: AD11205-55 Matrix: Drinking Water Sampled: 02/15/25 10:07:00									
Metals									
Lead	1.52		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-DW-02-203 Lims Reference ID: AD11205-57 Matrix: Drinking Water Sampled: 02/15/25 10:13:00									
Metals									
Lead	1.37		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-DW-02-200 Lims Reference ID: AD11205-59 Matrix: Drinking Water Sampled: 02/15/25 10:18:00									
Metals									
Lead	2.87		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TATE-DW-03-305 Lims Reference ID: AD11205-61 Matrix: Drinking Water Sampled: 02/15/25 10:22:00									
Metals									
Lead	1.68		1	1.00	µg/L	03/06/25 09:47	03/10/25 23:36	PL	EPA 200.8 (DA)/EPA 200.8

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Tatem Elementary School

Customer PO:

NJ-DOE 24-1117C

EMSL Sales Rep:

Justin Monturano

Received:

02/26/2025 12:00

Reported:

03/12/2025 13:08

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: TATE-DW-03-301

Lims Reference ID: AD11205-63 Matrix: Drinking Water

Sampled: 02/15/25 10:24:00

Metals

Lead	1.09	1	1.00	µg/L	03/06/25 09:47	03/10/25 23:37	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012511205
LIMS Reference ID: AD11205
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Tatem Elementary School

Customer PO: NJ-DOE 24-1117C
EMSL Sales Rep: Justin Monturano
Received: 02/26/2025 12:00
Reported: 03/12/2025 13:08

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2025
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012511205
LIMS Reference ID: AD11205
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Tatem Elementary School

Customer PO:

NJ-DOE 24-1117C

EMSL Sales Rep:

Justin Monturano

Received:

02/26/2025 12:00

Reported:

03/12/2025 13:08

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Abil205

Environmental Chemistry Chain of Custody EMSL Order Number (Lab Use Only):

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

Report To Contact Name: James Eberts				Bill To Company: Epic Environmental Services, LLC							
Company Name: Epic Environmental Services, LLC				Attention To: James Eberts / Timothy Eberts							
Street: 80 Fork Bridge Road				Street: 80 Fork Bridge Road							
City: Pittsgrove		State/Province: NJ		Zip/Postal Code: 08318		City: Pittsgrove					
Phone: 856-205-1077		Fax:		Phone: 856-205-1077		Fax:					
Project Name: Tatem Elementary School				Email Results To: jeberts@epicenviro.com / teberts@epicenviro.com							
U.S. State where Samples Collected: NJ				Number of Samples in Shipment: 64							
Sample for Compliance? Yes ☒ No ☐ If yes, NPDES? ☐ Other (Specify):				Samples Received Chilled (Y/N):							
Samples Collected by: EMSL ☐ Client ☒ check one				Sampled By (Signature): James Eberts							
Standard Turnaround Time: ☒ 2 Weeks				The following TATs are subject to lab approval: ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day							
Failure to complete will hinder processing of samples				List Test(s) Needed							
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix	Preservative	EPA 200.8 Total Lead	Field pH	Field pH Test Time	Field Temp. Deg C	Field Temp. Test Time	Comments
TATE -FB	☐	☒	0858	W	2	X					
KC-KITCH 1	☐	☒	0900	W		X					
KC-KITCH 2	☐	☒	0901	W		X					
KC-KITCH 2	☐	☒	0900	W		X					
(Flush)	☐	☒	0901	W		X					
Released By (Signature)	Date & Time			Received By			Date & Time				
James Eberts	2/26/25			James Eberts			2/26/25 12pm				

Please indicate reporting requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Disk Deliverable ☐ Other

Instructions or Comments: Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.

Analyze FIRST DRAW Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb

Page 1 of 5 pages (Lab) Received Temperature: °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS • TRAINING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS • TRAINING

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):
AD11205

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed				Comments	
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
KC-KITCH3	☐	☐	2/15/25	W	2							
↓ (Flush)	☐	☐	0901	W								
NS-01-NUSE	☐	☐	0905	W								
↓ (Flush)	☐	☒	0906	W								
WC-01-HAL1	☐	☒	0908	W								
WC-01-HAL2	☐	☒	0908	W								
BF-01-HAL2	☐	☒	0908	W								
WC-01-HAL3	☐	☒	0913	W								
TL-01-FACUC	☐	☒	0914	W								
↓ (Flush)	☐	☒	0915	W								
SO-01-LIBOF	☐	☒	0917	W								
↓ (Flush)	☐	☒	0918	W								
CS-02-211	☐	☒	0921	W								
↓ (Flush)	☐	☒	0922	W								
CS-02-209	☐	☒	0923	W								
↓ (Flush)	☐	☒	0924	W								
WC-02-HAL2	☐	☒	0925	W								

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry

Chain of Custody

EMSL Order Number (Lab Use Only):

AD1205

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed				Comments	
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
CS-02-210	☐	☐	2/15/25	W	2	1						
↓ (Flask)	☐	☐	0925	W								
CS-02-208	☐	☐	0926	W								
↓ (Flask)	☐	☐	0925	W								
CS-03-311	☐	☐	0926	W								
↓ (Flask)	☐	☐	0929	W								
CS-03-309	☐	☐	0930	W								
↓ (Flask)	☐	☐	0931	W								
WC-03-HALL	☐	☐	0932	W								
BE-03-HALL	☐	☐	0932	W								
CS-03-310	☐	☐	0933	W								
↓ (Flask)	☐	☐	0934	W								
CS-03-308	☐	☐	0934	W								
↓ (Flask)	☐	☐	0935	W								
CS-02-207	☐	☐	0937	W								
↓ (Flask)	☐	☐	0938	W								
CS-03-307	☐	☐	0939	W								

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS & TRAINING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS & TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AP11205

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples	Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments
	CS-03-307 (Flush)	☐	☐	2/15/25	W	2	1						
	WC-02-HALL 1	☐	☐	0942	W		1						
	WC-03-HALL 2	☐	☐	0943	W		1						
	CS-02-204	☐	☐	0945	W		1						
	↓ (Flush)	☐	☐	0946	W		1						
	CS-03-304	☐	☐	0947	W		1						
	↓ (Flush)	☐	☐	0948	W		1						
	DW-01-102	☐	☐	0953	W		1						
	↓ (Flush)	☐	☐	0954	W		1						
	DW-01-103	☐	☐	0955	W		1						
	↓ (Flush)	☐	☐	0956	W		1						
	DW-01-101	☐	☐	0959	W		1						
	↓ (Flush)	☐	☐	1000	W		1						
	DW-02-205	☐	☐	1004	W		1						
	↓ (Flush)	☐	☐	1005	W		1						
	DW-02-202	☐	☐	1007	W		1						
	↓ (Flush)	☐	☐	1008	W		1						

(Lab) Received Temperature: _____ °C



EMSL Order Number (Lab Use Only):

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

[illegible]

(Lab) Received Temperature: _____ °C